

Warranty & life time statement

aquatherm orange system

underfloor heating

aquatherm green pipe

pipe system

aquatherm lilac pipe

pipe system for recycled
reclaimed water

aquatherm blue pipe

pressure pipe system for
chilled and hot applications

aquatherm red pipe

sprinkler pipe system

aquatherm GmbH manufacture all pipes and fittings in accordance with the German DIN confirming a 50 year guarantee of service life in accordance with the permissible working pressure / temperature of their technical product manuals. Within the scope of this, aquatherm will supply replacement material pipe and fittings if damages are traceable to materials faults and defects.

Liability Warranty

furthermore within the scope of the aquatherm GmbH gives a 10 year guarantee which compensates for material damage to third persons, for investigation, removal, replacement, acceptance, dismantling or laying bare of all defective goods.

aquatherm GmbH guarantee is conditional on:

- The fusion of joining of pipe and fittings using only aquatherm GmbH welding tools and devices.
- Installation of pipe and fittings are certified aquatherm installers and adherence to aquatherm GmbH technical rules and guidelines for correct installation principles.

Limits of Liability

- **For bodily injury** 20.000.000 Euro
- **For property damage** 20.000.000 Euro
[per occurrence]

Installation Address:

Description of Installation:

Name of Plumber:

Signature:

Date of Completion:

Reg. Installer Number:

This warranty must be fully completed, signed and returned with the completed test sheet within three months of the completion of the project installation to the New Zealand Agent.

aquatherm® NZ limited, P.O. Box 99 393, Newmarket, Auckland, New Zealand. Phone 09 5707204, Fax 09 570 7206

aquatherm NZ Test record - aquatherm green pipe installation principles

Description of the Installation	
Street Address	
Suburb	
City	
Type of Installation	Domestic
	Commercial
Type of Pipe	aquatherm green pipe
	aquatherm blue pipe
	aquatherm lilac pipe
	aquatherm red pipe
	aquatherm grey pipe
	aquatherm orange system
Time testing Started	
Time testing finished	
Test period (minutes)	
Client:	
Contractor:	
Installers #:	Date:
Declaration:	
I declare that I have installed the above product in accordance with aquatherm specifications with no branding mix	
Signature:	

aquatherm® NZ limited must receive this information within 3 months of the installation for the warranty to be valid. Please consult with your local area Council as they may require a copy of the test results for the records.

Preliminary Test
[Testing procedure NZ January 2001]
Test pressure - 20 bar:

1. Test pressure 20 bar 10 minutes.
2. Unpressurise for 1 minute.
3. Test pressure 20 bar 5 minutes.
4. Unpressurise for 1 minute.
5. Test pressure 20 bar for 5 minutes.
6. Unpressurise.

WARNING

It is imperative to have movement during test period. Tight clips or damaged pipes in frame work will result in an incomplete test which will result in the warranty being invalid.

Result preliminary test:

The test is to be conducted as a continuous test as 20 bar with the five steps noted above.

The system **MUST** be pressurised **THREE TIMES** with a minimum rest of one minute between re-pressurising.

If leaking occurs, please replace the part and re-start the testing procedure.

The test is complete and acceptable when the above has been undertaken and no leaks are present.

Finally, complete all parts for the test sheet and return a copy to:

aquatherm NZ Limited

P.O. Box 99393,
Newmarket,
Auckland 1149